



RUBBER PARK INDIA (PVT) LTD
(A JV of KINFRA & Rubber Board)

2 A, "Kautileeyam", Rubber Park, Valayanchirangara,P.O, Ernakulam, Kerala-683 556.
Tel: (0484) 2657218/ 2655548 |Email: md@rubberparkindia.org | Web: www.rubberparkindia.org

Corrigendum-6: Addendum- 3

Tender No: RP/E/T/03/2024-25.

Tender ID: 2024_RPI_690380_2.

Name of Work: Design Supply Installation Testing and Commissioning of Grid Connected Battery Energy Storage System (BESS) of 500 kW/1 MWh at Rubber Park Irapuram., Ernakulam District.

Date: 27/09/2024

The following addendum/modification is made in the tender document. All other terms and conditions as stated in the tender document including the corrigendum's will remain unchanged.

Sl. No.	Tender Clause No.	As per Tender	Revised
01	Annexure-3, Sl. No. 28	Bidders to deploy Energy meter of 0.5 class accuracy, Interface meter (ABT Meter) for recording export/import energy from/to BESS including CTs and PTs used in the energy metering at POC point of BESS. In addition, energy meters of 0.5 class accuracy shall be provided for Aux. power supply. All Energy Meters shall be integrated with BESS EMS System.	Bidders to deploy Energy meter of 0.2s class accuracy, Interface meter (ABT Meter) for recording export/import energy from/to BESS including 0.2s class CTs and 0.2 class, PTs used in the energy metering at POC point of BESS. In addition, energy meters of 0.5 class accuracy shall be provided for Aux. power supply. All Energy Meters shall be integrated with BESS EMS System.

Dated: 27.09.2024

Place: Irpauram

Sd/-
Managing Director
Rubber Park India (P) Ltd