



**RUBBER PARK INDIA (PVT) LTD**  
(A JV of KINFRA & Rubber Board)

2 A, “Kautileeyam”, Rubber Park, Valayanchirangara,P.O, Ernakulam, Kerala-683 556.  
Tel: (0484) 2657218/ 2655548 |Email: md@rubberparkindia.org | Web: [www.rubberparkindia.org](http://www.rubberparkindia.org)

**CORRIGENDUM-4**

**Tender No:** RP/E/T/01/2025-26.

**Tender ID:** 2025\_RPI\_760507\_1.

**Name of Work:** Design, Supply, Installation, Testing and Commissioning of 400 kWp Grid Connected Solar Plant at Rubber Park, Irapuram on Turn Key basis.

The following Corrigendum/Addendum/Clarification shall form an integral part of bid document and it may amount to an amendment of relevant Para/clause of the bid document.

Sl. No.	Clause No.	Addendum
1	Section 9, Clause 9.34	The successful bidder shall be required to meet minimum guaranteed generation with <b>Performance Ratio (PR)</b> and <b>related Capacity Utilization Factor (CUF)</b> as per the GHI levels of the location during the Defect liability period. The <b>PR</b> should be shown a <b>minimum of 75% during the defect liability period (DLP)</b> . The <b>Minimum CUF shall not be less than 21% during the defect liability period (DLP)</b> . The bidder should send the monthly report with plant output details to the Owner/Client for ensuring the CUF. Any instances of grid failure need to be mentioned in the monthly report and those instances need to be authorised by the Owner/Client. Then the period will be excluded in calculation of CUF.

Dated: 05.05.2025  
Place: Irpauram

Sd/-  
**Managing Director**  
Rubber Park India (P) Ltd