



RUBBER PARK INDIA (PVT) LTD
(A JV of KINFRA & Rubber Board)

2 A, "Kautileeyam", Rubber Park, Valayanchirangara, P.O, Ernakulam, Kerala-683 556.
Tel: (0484) 2657218/ 2655548 | Email: md@rubberparkindia.org | Web: www.rubberparkindia.org

Corrigendum-7: Addendum- 4

Tender No: RP/E/T/03/2024-25.

Tender ID: 2024_RPI_690380_2.

Name of Work: Design Supply Installation Testing and Commissioning of Grid Connected Battery Energy Storage System (BESS) of 500 kW/1 MWh at Rubber Park Irapuram., Ernakulam District.

Date: 30/09/2024

The following addendum/modification is made in the tender document. All other terms and conditions as stated in the tender document including the corrigendum's will remain unchanged.

Sl. No.	Tender Clause No.	As per Tender	Revised
01	Annexure-3, Sl. No. 14 (iv)	The applicable standards are IS -2026 & Specification for Power Transformers, IEC 76.	The applicable standards are IS -2026 & Specification, IEC 76 for Power Transformers and IS 1180 (Part- I): 2014 for Outdoor Type Oil Immersed Distribution Transformers up to and including 2500kVA.

Dated: 30.09.2024

Place: Irpauram

Sd/-
Managing Director
Rubber Park India (P) Ltd