

2 A, "Kautileeyam", Rubber Park, Valayanchirangara,P.O, Ernakulam, Kerala-683 556. Tel: (0484) 2657218/ 2655548 |Email: md@rubberparkindia.org | Web: <u>www.rubberparkindia.org</u>

Corrigendum No.9 -Addendum-5

Tender No: RP/E/T/03/2024-25.

Tender ID: 2024_RPI_690380_2.

Name of Work: Design Supply Installation Testing and Commissioning of Grid Connected Battery Energy Storage System (BESS) of 500 kW/1 MWh at Rubber Park Irapuram., Ernakulam District.

The following addendum/modification is made in the guaranteed technical particulars (GTP) of Transformer and RMU in the tender document. All other terms and conditions as stated in the tender document shall remain unaltered unless expressly amended by corrigendum's.

Date: 08.10.2024 **Place:** Irpauram

Sd/-

Managing Director Rubber Park India (P) Ltd

IDT - Specifications			
Sl. No.	Description	Technical Specification	
1	Reference standards	Level-II (Star-1) as per IS 1180 (Part 1) 2014	
2	Application	Outdoor IDT (K factor ≥ 4)	
3	Type of Transformer	Oil Type	
4	Type of Installation	Outdoor	
5	Duty	Continuous	
6	Voltage ratio	11 kV/ 433 V or 11kV / 660V (LT side Voltage suitable for the design of the BESS)	
7	Rated frequency	50 Hz	
8	Number of phases	3	
9	Connections (HV/LV)	Delta/star	
10	Vector group reference	Dyn11	
11	Type of tap changer	Off circuit Tap Links	
12	Tapping on HV side	+5% to -10% in steps of 2.5%	
13	Reference Ambient Temperature	40Deg.C	
14	Type of cooling	ONAN	
15	Core type	CRGO /Amorphous	
16	Winding material	Copper	
17	Terminal arrangements	Cable for HV & LV side	

	Sd/-
MD Rubber	Park India P Ltd

	11kV RMU for BESS			
Sl. No.	Description	Technical Specification		
1	Make	ABB, Crompton Greaves, Lucy Electric, Siemens, Schneider, L&T		
2	Туре	Outdoor Type RMU (2 LBS +1VCB)		
3	Rated Voltage	12 kV		
4	Operation voltage:	11kV		
5	Rated lightning withstand voltage	75kVp		
6	Rated Power-frequency withstand	28kV, 1 min		
7	Rated Frequency	50Hz		
8	Rated Peak Current	50kA peak		
9	Rated short-time current	21kA		
10	Rated short -time	3 sec		
11	Operation	Manual and Motorized		
12	Protection	Self-powered O/C and EF protection relay. Suitable CTs & PTs shall be designed and proposed.		
14	Rated short circuit making capacity	52.5 kA		
15	Remote monitoring and control	Yes (FRTU).		
16	IP Rating	IP 67 for gas tank IP54 for enclosure IP 4X for low-voltage compartment		
17	Internal Arc test	20kA, 1 sec		
18	Rated Normal Current of Incomer Load Break Switch and Circuit – breaker(VCB)	630 A		
19	Switching Capacity of VCB	As per IEC 62271-100		
20	Switching capacity of Earthing Switch	As per IEC 62271-102		
21	Stainless Steel Tank	The tank shall be robotically welded and made of stainless steel material conforming to IP 67 degree of protection and the thickness of all sides shall be not be less than 2.5 mm.		

Sd/-

MD Rubber Park India P Ltd